

Customer:

Site:

PASS

Fire Damper No	N2sply015
Department	Undergraduate centre
Floor	2
Room Number	Uc243
Drawing	Yes

Supply/Extract/Recir	S
Dirty Environment	Clean
Damper Type	Fire Damper
Static Dynamic	Fusible Link

Accessible For Test	Yes
Access Height (m)	Above 3.5 meter
Access Comments	
Damper Position At Inspection	Open
Drop Successful?	Yes
Reset Successful?	Yes
Damper Condition	Good
Duct Cleanliness	Good
Damper Pass/Fail	Pass
Remedial Recommendations	N/A
Next Test	1 year



Before



After